

Autumn Ridge Subdivision – Notice to Bidders

January 3, 2019

1. Looking at the most current March 2018 MDOT Materials Source Guide, I don't see any reference to any kind of "collar w/ thermoplastic molding" in section 909 for the MANHOLE COVER, COLLAR bid item. Could you please provide a better description or reference?
 - a. Please see Addendum #1 with updated Special Provision for the Manhole Cover, Collar.

2. Do you have a current cross section of the existing asphalt?
 - a. No, we do not. Based on old plans, the HMA is 3.5" throughout the entire subdivision.

3. Are we removing/milling all of the asphalt out or milling for the 3.5" cross section?
 - a. We are planning on removing all of the asphalt, which is estimated at 3.5" thickness throughout the subdivision.